




APPENDIX J

Lead Based Paint Sample Locations







Landmark Environmental, Inc. Building Inspection Form

250 Bryant Street ♦ Denver, Colorado 80219 ♦ 720-283-8975 ♦ Fax: 720-283-8666

Project: Truman Farm 11027.001.001	Client: Anderson Hallas Architects	Date: 12/06/11 Inspector(s): M. Roberts
---------------------------------------	---------------------------------------	--

Sample #	Location:	Component	Substrate	Color	% Pb
TFH-120611-LBP1-01	Closet @ Dining RM	Wall	Plaster	Tan	0.003
TFH-120611-LBP2-01	Door @ Stair	Door	Wood	Tan/Gray	0.174
TFH-120611-LBP3-01	SW Cnr Dining Rm	Wall	Plaster	Tan/Green	0.651
TFH-120611-LBP4-01	HST Bedroom	Wall	Plaster	Green/Gray	0.016
TFH-120611-LBP5-01	HST Bedroom	Trim	Wood	Brn/Green	0.003
TFH-120611-LBP6-01	N Wall Basement	Window	Wood	White	19.33
TFH-120611-LBP7-01	Front Door Ext.	Door	Wood	White	5.859
TFH-120611-LBP8-01	Exterior Trim	Trim	Wood	Green	0.005
TFH-120611-LBP9-01	Exterior Garage	Trim	Wood	White	25.42
TFH-120611-LBP10-01	Exterior Upper Trim	Trim	Wood	Green	22.01

RESERVOIRS ENVIRONMENTAL, INC.
 5801 Logan St., Suite 100
 Denver CO 80216

TABLE ANALYSIS: LEAD IN PAINT

RES Job Number: RES 225616-1
 Client: Landmark Environmental, Inc.
 Client Project Number / P.O.: 11027.001.001
 Client Project Description: Truman Farm
 Date Samples Received: December 8, 2011
 Analysis Type: USEPA SW846 3050B / AA (7420)
 Turnaround: 3-5 Day
 Date Samples Analyzed: December 9, 2011

Client ID Number	Lab ID Number	Reporting Limit (%)	LEAD CONCENTRATION (%)
TFH-120611-LBP1-01	EM 834186	0.002	0.003
TFH-120611-LBP2-01	EM 834187	0.004	0.174
TFH-120611-LBP3-01	EM 834188	0.005	0.651
TFH-120611-LBP4-01	EM 834189	0.003	0.016
TFH-120611-LBP5-01	EM 834190	0.003	0.003
TFH-120611-LBP6-01	EM 834191	0.005	19.33
TFH-120611-LBP7-01	EM 834192	0.005	5.859
TFH-120611-LBP8-01	EM 834193	0.004	0.005
TFH-120611-LBP9-01 (Labeled TFG-120611-LBP9-01)	EM 834194	0.003	25.42
TFH-120611-LBP10-01	EM 834195	0.003	22.01

* Unless otherwise noted all quality control samples performed within specifications established by the laboratory.

BRL = Below Reporting Limit

Page 2 of 2

Data Qa

df
 Digitally signed by Data Qa
 DN: cn=Data Qa, o=RES
 2011.12.09 15:52:35 -0700

