


03/08/2019

Olympic National Park
600 East Park Ave
Port Angeles, WA 98362

Project: Enchanted Valley Chalet
Client ID: Kitchen Cupboard
Sample Matrix: Paint Chips
Date Sampled: 08/25/2018
Date Received: 08/30/2018
Spectra Project: 2018080728
Spectra Number: 1


<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>
SPLP Lead	0.031	mg/L	EPA 1312/6010D
TCLP Lead	0.066	mg/L	SW846 6010D
Total Lead	562	mg/Kg	SW846 6010D

SPECTRA LABORATORIES



Jeffrey Cooper, Laboratory Manager

ab/scj




03/08/2019


Olympic National Park
600 East Park Ave
Port Angeles, WA 98362

Project: Enchanted Valley Chalet
Client ID: Window Sill
Sample Matrix: Paint Chips
Date Sampled: 08/25/2018
Date Received: 08/30/2018
Spectra Project: 2018080728
Spectra Number: 2

<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>
SPLP Lead	0.030	mg/L	EPA 1312/6010D
TCLP Lead	0.070	mg/L	SW846 6010D
Total Lead	225	mg/Kg	SW846 6010D

SPECTRA LABORATORIES


Jeff Cooper, Laboratory Manager
jco/scl




03/08/2019

Olympic National Park
600 East Park Ave
Port Angeles, WA 98362


Project: Enchanted Valley Chalet
Client ID: Shutter
Sample Matrix: Paint Chips
Date Sampled: 08/25/2018
Date Received: 08/30/2018
Spectra Project: 2018080728
Spectra Number: 3

<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>
SPLP Lead	< 0.025	mg/L	EPA 1312/6010D
TCLP Lead	< 0.025	mg/L	SW846 6010D
Total Lead	13.3	mg/Kg	SW846 6010D

SPECTRA LABORATORIES


Johnny Cooper, Laboratory Manager

nt/scj




03/08/2019

Olympic National Park
600 East Park Ave
Port Angeles, WA 98362

Project: Enchanted Valley Chalet
Client ID: Floor
Sample Matrix: Paint Chips
Date Sampled: 08/25/2018
Date Received: 08/30/2018
Spectra Project: 2018080728
Spectra Number: 4

<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>
SPLP Lead	< 0.025	mg/L	EPA 1312/6010D
TCLP Lead	0.610	mg/L	SW846 6010D
Total Lead	1790	mg/Kg	SW846 6010D

SPECTRA LABORATORIES


Jeremy Cooper, Laboratory Manager


03/08/2019

Olympic National Park
600 East Park Ave
Port Angeles, WA 98362

Project: Enchanted Valley Chalet
Client ID: Mural
Sample Matrix: Paint Chips
Date Sampled: 08/25/2018
Date Received: 08/30/2018
Spectra Project: 2018080728
Spectra Number: 5

<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>
SPLP Lead	0.113	mg/L	EPA 1312/6010D
TCLP Lead	0.50	mg/L	SW846 6010D
Total Lead	1640	mg/Kg	SW846 6010D

SPECTRA LABORATORIES



Jeffrey Cooper, Laboratory Manager


03/08/2019

Olympic National Park
600 East Park Ave
Port Angeles, WA 98362

Project: Enchanted Valley Chalet
Client ID: Stairs
Sample Matrix: Paint Chips
Date Sampled: 08/25/2018
Date Received: 08/30/2018
Spectra Project: 2018080728
Spectra Number: 6


<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>
SPLP Lead	0.120	mg/L	EPA 1312/6010D
TCLP Lead	0.85	mg/L	SW846 6010D
Total Lead	930	mg/Kg	SW846 6010D

SPECTRA LABORATORIES



Jeffrey Cooper, Laboratory Manager

at6acj




03/08/2019


Olympic National Park
600 East Park Ave
Port Angeles, WA 98362

Project: Enchanted Valley Chalet
Client ID: Door
Sample Matrix: Paint Chips
Date Sampled: 08/25/2018
Date Received: 08/30/2018
Spectra Project: 2018080728
Spectra Number: 7

<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>
SPLP Lead	< 0.025	mg/L	EPA 1312/6010D
TCLP Lead	< 0.025	mg/L	SW846 6010D
Total Lead	40.4	mg/Kg	SW846 6010D

SPECTRA LABORATORIES


Jeffrey Cooper, Laboratory Manager




03/08/2019

Olympic National Park
600 East Park Ave
Port Angeles, WA 98362

Project: Enchanted Valley Chalet
Client ID: Kitchen Wall/Bead Board
Sample Matrix: Paint Chips
Date Sampled: 08/25/2018
Date Received: 08/30/2018
Spectra Project: 2018080728
Spectra Number: 8

<u>Analyte</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>
SPLP Lead	< 0.025	mg/L	EPA 1312/6010D
TCLP Lead	0.072	mg/L	SW846 6010D
Total Lead	52	mg/Kg	SW846 6010D

SPECTRA LABORATORIES


Jeffrey Cooper, Laboratory Manager